

SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

June 16, 2017

Val Belmonte
Winson Knolls Education Group
2353 Hassell Road, Suite 110
Hoffman Estates, IL 60169

Workorder: 1706316

TEL: (630) 283-3221

FAX: (630) 283-3482

RE: Drinking Water Lead Analysis

Dear Val Belmonte:

Suburban Laboratories, Inc. received 12 sample(s) on 6/6/2017 for the analyses presented in the following report.

Customer has provided 250 mL volume sample bottles for all samples collected. Please note, all sample results that exceed 5.00 ug/L should be promptly reported to parents or guardians of all enrolled students. Results that are below 5.00 ug/L should be reported on the school website. Please refer to Public Act 099-0922 or the Illinois Department of Public Health for specific reporting requirements. Suburban Laboratories will forward all results to the IDPH within seven (7) business days from the date of this report.

This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc. If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,



Pat Rodriguez
Project Manager
708-544-3260 ext 214
pat@suburbanlabs.com



SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134

Tel. (708) 544-3260 • Toll Free (800) 783-LABS

Fax (708) 544-8587

www.suburbanlabs.com

Report Date: June 16, 2017

Workorder: 1706316

Client ID: Winson Knolls Education Group

Project Name: Drinking Water Lead Analysis

Analyte: Lead

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1706316-001A	TL SINK 1	ND	2.00	µg/L	05/25/17 16:00	5/26/2017	6/13/2017
1706316-002A	TL SINK 2	ND	2.00	µg/L	05/25/17 16:00	5/26/2017	6/13/2017
1706316-003A	SL SINK 1	ND	2.00	µg/L	05/25/17 16:00	5/26/2017	6/13/2017
1706316-004A	SL SINK 2	ND	2.00	µg/L	05/25/17 16:00	5/26/2017	6/13/2017
1706316-005A	NHFT 1	ND	2.00	µg/L	05/25/17 16:00	5/26/2017	6/13/2017
1706316-006A	NHFT 2	ND	2.00	µg/L	05/25/17 16:00	5/26/2017	6/13/2017
1706316-007A	NHFL 1	ND	2.00	µg/L	05/25/17 16:00	5/26/2017	6/13/2017
1706316-008A	NHFL 2	ND	2.00	µg/L	05/25/17 16:00	5/26/2017	6/13/2017
1706316-009A	OTFT 1	ND	2.00	µg/L	05/25/17 16:00	5/26/2017	6/13/2017
1706316-010A	OTFT 2	ND	2.00	µg/L	05/25/17 16:00	5/26/2017	6/13/2017
1706316-011A	OTFL 1	ND	2.00	µg/L	05/25/17 16:00	5/26/2017	6/13/2017
1706316-012A	OTFL 2	ND	2.00	µg/L	05/25/17 16:00	5/26/2017	6/13/2017

ND - Not Detected Down to the Laboratory Minimum Reporting Limit (MRL)



SUBURBAN LABORATORIES, Inc.

CHAIN OF CUSTODY RECORD

Electronic Version

1950 S Batavia Ave Ste 150 Geneva IL 60134 Tel. 708.544.3260 Fax: 708.544.8587 Toll Free: 800.783.LABS www.suburbanlabs.com

Company Name: Winston Knolls

Company Address: 8353 Hassell RD State: IL Zip: 60169

City: Hoffman Est Phone: 630/283-3222 Fax: 630/283-3282 Fax Report:

Project ID/Location: Drinking Water Lead Analysis

Project Manager (Report to): William Emms Sample Collector(s): William Emms HL Director

TURNAROUND TIME REQUESTED: Normal RUSH* (charges apply) *Additional Rush pre-approval and additional charges apply.

Specify Regulatory Program: LUST SRP SDWA 503 Sludge NPDES MWRDGC Disposal Other (specify in comment below)

DATE AND TIME THE WATER SYSTEM WAS LAST USED BEFORE SAMPLE COLLECTION: 7/26/13 4:00pm

SAMPLE IDENTIFICATION	COLLECTION		MATRIX	GRAB/COMP.	CONTAINERS	PRESERVATIVE	ANALYSIS & METHOD REQUESTED
	DATE	TIME					
1 TL SINK 1	7/26/13	7:18am	DW	G	1 250 mL Plastic	Unpreserved	X
2 TL SINK 2	7/26/13	7:18am	DW	G	1 250 mL Plastic	Unpreserved	X
3 SL SINK 1	7/26/13	7:18am	DW	G	1 250 mL Plastic	Unpreserved	X
4 SL SINK 2	7/26/13	7:21am	DW	G	1 250 mL Plastic	Unpreserved	X
5 NH FT 1	7/26/13	7:22am	DW	G	1 250 mL Plastic	Unpreserved	X
6 NH FT 2	7/26/13	7:25am	DW	G	1 250 mL Plastic	Unpreserved	X
7 NH FL 1	7/26/13	7:30am	DW	G	1 250 mL Plastic	Unpreserved	X
8 NH FL 2	7/26/13	7:31am	DW	G	1 250 mL Plastic	Unpreserved	X
9 OT FT 1	7/26/13	7:34am	DW	G	1 250 mL Plastic	Unpreserved	X
10 OT FT 2	7/26/13	7:35am	DW	G	1 250 mL Plastic	Unpreserved	X
11 OT FL 1	7/26/13	7:40am	DW	G	1 250 mL Plastic	Unpreserved	X
12 OT FL 2	7/26/13	7:41am	DW	G	1 250 mL Plastic	Unpreserved	X

COMMENTS & SPECIAL INSTRUCTIONS: PLEASE COMPLETE THE HIGHLIGHTED SECTIONS

CONDITION CODES: 1. Improper/damaged container/stop 2. Improper preservation 3. Insufficient sample volume 4. Headspace/air bubbles for VOCs 5. Received past holding time 6. Received frozen 7. Label conflicts with COC

DATE AND TIME THE WATER SYSTEM WAS LAST USED BEFORE SAMPLE COLLECTION: 7/26/13 4:00pm

1. Relinquished By: [Signature] Date: 7/26/13

2. Relinquished By: [Signature] Date: 7/26/13

3. Relinquished By: [Signature] Date: 7/26/13

4. Relinquished By: [Signature] Date: 7/26/13

Submission of samples subject to Terms and Conditions on back. Rev. 7/20/08 Please fill out this form completely, print, sign & submit with samples. Keep a copy for your records.